

**Supervision Practices**  
**International Building Code (2003)**

**TABLE 1704.3**  
**REQUIRED VERIFICATION AND INSPECTION OF STEEL CONSTRUCTION**

VERIFICATION AND INSPECTION	CONTINUOUS	PERIODIC	REFERENCED STANDARD <sup>a</sup>	IBC REFERENCE
1. Material verification of high-strength bolts, nuts and washers:				
a. Identification markings to conform to ASTM standards specified in the approved construction documents.	—	X	Applicable ASTM material specifications; AISC 335, Section A3.4; AISC LRFD, Section A3.3	—
b. Manufacturer's certificate of compliance required.	—	X	—	—
2. Inspection of high-strength bolting:				
a. Bearing-type connections.	—	X	AISC LRFD Section M2.5	1704.3.3
b. Slip-critical connections.	X	X		
3. Material verification of structural steel:				
a. Identification markings to conform to ASTM standards specified in the approved construction documents.	—	—	ASTM A 6 or ASTM A 568	1708.4
b. Manufacturers' certified mill test reports.	—	—	ASTM A 6 or ASTM A 568	
4. Material verification of weld filler materials:				
a. Identification markings to conform to AWS specification in the approved construction documents.	—	—	AISC, ASD, Section A3.6; AISC LRFD, Section A3.5	—
b. Manufacturer's certificate of compliance required.	—	—	—	—
5. Inspection of welding:				
a. Structural steel:	—	—		
1) Complete and partial penetration groove welds.	X	—	AWS D1.1	1704.3.1
2) Multipass fillet welds.	X	—		
3) Single-pass fillet welds $> \frac{5}{16}$ "	X	—		
4) Single-pass fillet welds $\leq \frac{5}{16}$ "	—	X		
5) Floor and deck welds.	—	X	AWS D1.3	—
b. Reinforcing steel:	—	—		
1) Verification of weldability of reinforcing steel other than ASTM A 706.	—	X	AWS D1.4 ACI 318: 3.5.2	1903.5.2
2) Reinforcing steel-resisting flexural and axial forces in intermediate and special moment frames, and boundary elements of special reinforced concrete shear walls and shear reinforcement.	X	—		
3) Shear reinforcement.	X	—		
4) Other reinforcing steel.	—	X		
6. Inspection of steel frame joint details for compliance with approved construction documents:		X		
a. Details such as bracing and stiffening.	—	—	—	1704.3.2
b. Member locations.	—	—		
c. Application of joint details at each connection.	—	—		

For SI: 1 inch = 25.4 mm.

a. Where applicable, see also Section 1707.1, Special inspection for seismic resistance.

**TABLE 1704.4  
REQUIRED VERIFICATION AND INSPECTION OF CONCRETE CONSTRUCTION**

VERIFICATION AND INSPECTION	CONTINUOUS	PERIODIC	REFERENCED STANDARD <sup>a</sup>	IBC REFERENCE
1. Inspection of reinforcing steel, including prestressing tendons, and placement.	—	X	ACI 318: 3.5, 7.1-7.7	1903.5, 1907.1, 1907.7, 1914.4
2. Inspection of reinforcing steel welding in accordance with Table 1704.3, Item 5B.	—	—	AWS D1.4 ACI 318: 3.5.2	1903.5.2
3. Inspect bolts to be installed in concrete prior to and during placement of concrete where allowable loads have been increased.	X	—	—	1912.5
4. Verifying use of required design mix.	—	X	ACI 318: Ch. 4, 5.2-5.4	1904, 1905.2-1905.4, 1914.2, 1914.3
5. At the time fresh concrete is sampled to fabricate specimens for strength tests, perform slump and air content tests, and determine the temperature of the concrete.	X	—	ASTM C 172 ASTM C 31 ACI 318: 5.6, 5.8	1905.6, 1914.10
6. Inspection of concrete and shotcrete placement for proper application techniques.	X	—	ACI 318: 5.9, 5.10	1905.9, 1905.10, 1914.6, 1914.7, 1914.8
7. Inspection for maintenance of specified curing temperature and techniques.	—	X	ACI 318: 5.11-5.13	1905.11, 1905.13, 1914.9
8. Inspection of prestressed concrete: a. Application of prestressing forces. b. Grouting of bonded prestressing tendons in the seismic-force-resisting system.	X X	—	ACI 318: 18.20 ACI 318: 18.18.4	—
9. Erection of precast concrete members.	—	X	ACI 318: Ch. 16	—
10. Verification of in-situ concrete strength, prior to stressing of tendons in posttensioned concrete and prior to removal of shores and forms from beams and structural slabs.	—	X	ACI 318: 6.2	1906.2

For SI: 1 inch = 25.4 mm.

<sup>a</sup> Where applicable, see also Section 1707.1, Special inspection for seismic resistance.

**TABLE 1704.5.1  
LEVEL 1 SPECIAL INSPECTION**

INSPECTION TASK	FREQUENCY OF INSPECTION		REFERENCE FOR CRITERIA			
	Continuous during task listed	Periodically during task listed	IBC section	ACI 530/ASCE 5/TMS 402 <sup>a</sup>	ACI 530.1/ASCE 6/TMS 602 <sup>a</sup>	
1. As masonry construction begins, the following shall be verified to ensure compliance:						
a. Proportions of site-prepared mortar.	—	X	—	—	Art. 2.6A	
b. Construction of mortar joints.		X			Art. 3.3B	
c. Location of reinforcement and connectors.		X			Art. 3.4, 3.6A	
d. Prestressing technique.	—	X	—	—	Art. 3.6B	
e. Grade and size of prestressing tendons and anchorages.	—	X	—	—	Art. 2.4B, 2.4H	
2. The inspection program shall verify:						
a. Size and location of structural elements.	—	X	—	—	Art. 3.3G	
b. Type, size and location of anchors, including other details of anchorage of masonry to structural members, frames or other construction.	—	X	—	Sec. 1.2.2(e), 2.1.4, 3.1.6	—	
c. Specified size, grade and type of reinforcement.	—	X	—	Sec. 1.12	Art. 2.4, 3.4	
d. Welding of reinforcing bars.	X	—	—	Sec. 2.1.10.6.2, 3.2.3.4(b)	—	
e. Protection of masonry during cold weather (temperature below 40°F) or hot weather (temperature above 90°F).	—	X	Sec. 2104.3, 2104.4	—	Art. 1.8C, 1.8D	
f. Application and measurement of prestressing force.	—	X	—	—	Art. 3.6B	
3. Prior to grouting, the following shall be verified to ensure compliance:						
a. Grout space is clean.	—	X	—	—	Art. 3.2D	
b. Placement of reinforcement and connectors and prestressing tendons and anchorages.		X			Sec. 1.12	Art. 3.4
c. Proportions of site-prepared grout and prestressing grout for bonded tendons.		X			—	Art. 2.6B
d. Construction of mortar joints.		X			—	Art. 3.3B
4. Grout placement shall be verified to ensure compliance with code and construction document provisions.	X	—	—	—	Art. 3.5	
a. Grouting of prestressing bonded tendons.	X	—	—	—	Art. 3.6C	
5. Preparation of any required grout specimens, mortar specimens and/or prisms shall be observed.	X	—	Sec. 2105.2.2, 2105.3	—	Art. 1.4	
6. Compliance with required inspection provisions of the construction documents and the approved submittals shall be verified.	—	X	—	—	Art. 1.5	

For SI: °C = (°F - 32)/1.8.

<sup>a</sup> The specific standards referenced are those listed in Chapter 35.

**TABLE 1704.5.3  
LEVEL 2 SPECIAL INSPECTION**

INSPECTION TASK	FREQUENCY OF INSPECTION		REFERENCE FOR CRITERIA		
	Continuous during task listed	Periodically during task listed	IBC section	ACI 530/ASCE 5/TMS 402 <sup>a</sup>	ACI 530.1/ASCE 6/TMS 602 <sup>a</sup>
1. From the beginning of masonry construction, the following shall be verified to ensure compliance:					
a. Proportions of site-prepared mortar, grout and prestressing grout for bonded tendons.	—	X	—	—	Art. 2.6A
b. Placement of masonry units and construction of mortar joints.	—	X	—	—	Art. 3.3B
c. Placement of reinforcement, connectors and prestressing tendons and anchorages.	—	X	—	Sec. 1.12	Art. 3.4, 3.6A
d. Grout space prior to grouting.	X	—	—	—	Art. 3.2D
e. Placement of grout.	X	—	—	—	Art. 3.5
f. Placement of prestressing grout.	X	—	—	—	Art. 3.6C
2. The inspection program shall verify:					
a. Size and location of structural elements.	—	X	—	—	Art. 3.3G
b. Type, size and location of anchors, including other details of anchorage of masonry to structural members, frames or other construction.	X	—	—	Sec. 1.2.2(e), 2.1.4, 3.1.6	—
c. Specified size, grade and type of reinforcement.		X	—	Sec. 1.12	Art. 2.4, 3.4
d. Welding of reinforcement.	X	—	—	Sec. 2.1.10.6.2, 3.2.3.4(b)	—
e. Protection of masonry during cold weather (temperature below 40°F) or hot weather (temperature above 90°F).	—	X	Sec. 2104.3, 2104.4	—	Art. 1.8C, 1.8D
f. Application and measurement of prestressing force.	X	—	—	—	Art. 3.6B
3. Preparation of any required grout specimens, mortar specimens and/or prisms shall be observed.	X	—	Sec. 2105.2.2, 2105.3	—	Art. 1.4
4. Compliance with required inspection provisions of the construction documents and the approved submittals shall be verified.	—	X	—	—	Art. 1.5

For SI: °C = (°F - 32)/1.8.

a. The specific standards referenced are those listed in Chapter 35.

1-26 *Design Considerations in the Use of Structural Timber*

### 1.6 HANDLING, STORAGE, ERECTION, AND SEASONING OF STRUCTURAL TIMBER

The erection of structural timber framing requires experienced erection crews and adequate lifting equipment to protect lives and property and to assure that the framing is not improperly assembled or damaged during handling. The unloading and storage of structural timber framing before erection also demands care and good judgment. It is suggested that a shipment of structural timber framing, on receipt at the job site, be checked for tally and damage. The following general precautions apply.

#### 1.6.1 Precautions During Unloading

Structural timber framing is subject to surface marring and damage when not properly handled and protected. At the erection site, the following precautions are suggested:

1. Lift members or roll them on dollies or rollers out of railroad cars; do not drag or drop them. Unload trucks by lifting from the truck; do not dump or drop members.
2. If unloading with lifting equipment, use wide fabric or plastic belts or other slings that will not mar wood. If chains or cables are used, provide protective blocking or padding to sharp edges or sharp corners.
3. Guard against soiling, dirt, footprints, or abrasions. If members are wrapped, avoid tearing or damaging the protective material.

#### 1.6.2 Precautions During Storage

If structural timber framing is to be stored before erection, it should be placed on blocks well off the ground, and individual members should be separated by strips so that air may circulate around all four sides. The top and all sides of storage piles should be covered with moisture-resistant material. Clear polyethylene films should not be used because wood members are subject to bleaching from sunlight. Individual wrappings should be slit or punctured on the lower side to permit drainage of water that may have accumulated. Water-resistant wrapping used for the in-transit protection of glued laminated members should be left intact until the members are enclosed within the building. If wrapping has to be removed at certain connection points during the erection, it should be replaced after the connection is made. If it is impractical to replace the wrapping, all of it should be removed to avoid the nonuniform appearance caused by sun and weather exposure.

#### 1.6.3 Precautions During Erection

##### 1.6.3.1 Assembly

Trusses are usually shipped partially or completely disassembled and are assembled on the ground at the site before erection. Arches, which are generally shipped in halves, may be assembled on the ground or connections may be made

# TIMBER CONSTRUCTION MANUAL

FOURTH EDITION  
1994

AMERICAN INSTITUTE OF TIMBER  
CONSTRUCTION

Englewood, Colorado



A WILEY-INTERSCIENCE PUBLICATION

JOHN WILEY & SONS, INC.

New York • Chichester • Brisbane • Toronto • Singapore

1.6 Handling, Storage, Erection, and Seasoning of Structural Timber 1-27

after the half arches are in position. When trusses and arches are assembled on the ground at the site, they should be assembled on level blocking to permit connections to be fitted properly and tightened securely without damage. The end compression joints should be brought into full bearing and compression plates installed where specified.

Before erection, the assembly should be checked for prescribed overall dimensions, prescribed camber, and accuracy of anchorage connections. Erection should be planned and executed in such a way that the close fit and neat appearance of joints and the structure as a whole will not be impaired.

Anchor bolts should be checked prior to the start of erection. Before erection begins, all supports and anchors should be complete, accessible, and free of obstructions. The weights and balance points of the structural timber framing should be determined before lifting begins so that proper equipment and lifting methods may be employed. When long members or timber trusses of long span are raised from a flat to a vertical position preparatory to lifting, stresses entirely different from the normal design stress may be introduced. The magnitude and distribution of these stresses will vary, depending on such factors as the weight, dimensions, and type of member. A competent rigger should consider these factors in determining how much suspension and stiffening, if any, is required and where it could be located.

#### 1.6.3.2 Bracing

All framing must be true and plumbed. Permanent bracing is bracing so designed and installed as to form an integral part of the final structure. Erection bracing is bracing installed to hold the framing in a safe position until sufficient permanent bracing is in place to provide full stability. Proper and adequate temporary erection bracing is introduced whenever necessary to take care of all loads to which the structure may be subjected during erection, including equipment and its operation. This bracing is left in place as long as may be required for safety. Part or all of the permanent bracing may also act as erection bracing. Erection bracing serves to plumb the framing during erection and gives it adequate stability to receive purlins, joists, and roofing materials. It may include sway bracing, guy ropes, tying off framing nearest to end walls, steel tie rods with turnbuckle take-ups, struts, shoes, and similar items. As erection progresses, bracing is securely fastened in place to take care of all dead load, erection stresses, and normal weather conditions. Excessive concentrated construction loads, such as bundles of sheathing, piles of purlins, roofing, or other materials, should be avoided.

#### 1.6.3.3 Final Alignment

Final tightening of alignment bolts should not be completed until the structure has been properly aligned.

#### 1.6.3.4 Removal of Temporary Bracing

Temporary erection bracing should be removed only after diaphragms and permanent bracing are installed, the structure has been properly aligned, and connections and fastenings have been finally tightened. Retightening of con-

1-28 Design Considerations in the Use of Structural Timber

nections prior to final completion or closing in of inaccessible connections is recommended.

#### 1.6.3.5 Field Connections

The joining, holding, and welding of steel connections in the field are performed according to the requirements for shop work of such operations, except where such requirements apply to shop conditions only. Steel connections should comply with the specifications of the American Institute of Steel Construction (18) and the American Welding Society (19).

#### 1.6.3.6 Protection of Field Cuts

All field cuts of timbers should be coated with an approved moisture seal if the member was initially coated unless otherwise specified. All field framing is done in accordance with the requirements of shop practice except where such requirements apply to shop conditions only. If timber framing has been pressure treated, field framing after treatment must be avoided or at least, insofar as possible, held to a minimum. When field cuts in pressure-treated material are unavoidable, additional treatment should be provided in accordance with AWPAC Standard M4 (10).

#### 1.6.3.7 Protection Against Moisture

During erection operations, all timber framing that requires moisture content control, whether sawn or glued laminated timbers, should be protected against moisture pickup. Any fabricated structural materials to be stored for an extended period of time before erection should, insofar as is practicable, be assembled into subassemblies for storage purposes.

#### 1.6.3.8 Seasoning Period

Heat should not be fully turned on as soon as the structure is enclosed; otherwise, excessive checking may occur due to rapid lowering of the relative humidity in the building. A gradual seasoning period at moderate temperature should be provided.